

Hibbing Public Utilities
Policy Number: CUST067custequip
Date: May 1, 2004

Subject: CUSTOMER ELECTRICAL EQUIPMENT

Customers must pay for the cost of maintenance and special installation necessary to meet their particular requirements for service outside of the HPUC's standard voltage and phase. Customers must pay for the supply of closer voltage regulation than furnished under the HPUC's standard policies.

Motor Service

Information as to the availability of service must be obtained from the HPUC Engineering Department.

The HPUC is not responsible for the voltage regulation for mixed light and power installations to a greater extent than required for power installation.

Motor Requirements

Motors frequently started or motors arranged for automatic control must be of a type to give maximum starting torque with minimum current, and must be equipped with controlling devices approved by the HPUC.

Maintenance of Electrical Equipment

All wiring and other electrical equipment on the premises and furnished by the customer must be maintained by the customer at all times in accordance with the requirements of the Minnesota Electrical Safety Code, the National Electric Code, and HPUC regulations.

Interference

A customer's electrical apparatus that is used in conjunction with and operated by energy furnished by the HPUC must be designed, constructed, installed, and operated so as not to interfere unreasonably with the HPUC's service to other customers. The HPUC may discontinue service to the customer until the conditions causing the interference are corrected.

