

Hibbing Public Utilities  
Policy Number: CUST062elecinstall  
Date: May 1, 2004

**Subject: ELECTRIC SERVICE INSTALLATIONS**

All electric service installations must be in accordance with the National Electric Code, except as modified by the HPUC's policies, procedures, and regulations for electric service and meter installations. Electric installations must adhere to the following requirements.

- 1) Service entrance equipment must comply with the National Electric Code
- 2) Conductors must extend at least 2 feet beyond the service head. A white braid covering or other approved means of identification must identify the grounded conductor.
- 3) The HPUC will make all service connections to the service entrance conductors.
- 4) All service wiring and conduit on the customer's side of the point of delivery must be installed by and at the expense of the customer.
- 5) Electric meters will be provided by the HPUC, and meter bases (sockets) will be provided by the customer.
- 6) After electric service has been established, any change in location of the service drop attachment that requires a change in HPUC facilities and is requested by the customer, will be at the customer's expense.

---

Adopted by Commission Action

