

Hibbing Public Utilities  
Policy Number: CUST015gasmeters  
Date: May 1, 2004

**Subject: NATURAL GAS SERVICE AND METERING TO A GARAGE**

No more than 1 single meter is allowed for a residential natural gas service. The meter can be either outside of the house or the garage. The HPUC does not allow a separate meter for the garage that is fed from an existing riser on the property (the house service) unless specifically approved. Second service runs from an existing riser are intended to supply a natural gas load that is less than the supply to the residence.

A second service run tapped from the main to the garage is typically the only option in which to meter a garage separately.

Approval to run a second service from the main to the garage for metering purposes must be obtained from the HPUC Director of Utility Operations.

---

Adopted by Commission Action