

Subject: WATER MAIN CONNECTIONS

The following requirements apply to 24-inch and the 30-inch water transmission line from Howard Street and 12th Avenue Ease via the East Beltline – 13th Avenue East to the 53rd Street Water Pump Booster Station.

- 1) Water distribution connections will be made only where existing connections are provided.
- 2) Water service tap connections are not allowed on the 24-inch and 30-inch water transmission line. Service taps will be made only on water distribution lines.
- 3) Customer and/or contractor must first obtain a written approval from the HPUC before any connections are made to the 24-inch and 30-inch water transmission line.
- 4) In order to facilitate emergency repairs, the materials used in a new development or extension of a water distribution line must be in accordance to HPUC Standards and Specifications. This includes but is not limited to pipe, fittings, valves, and fire hydrants.
- 5) All required permits and licenses will be obtained from the affected government agency or body (city, township, county, state) before water service work begins.
- 6) All backfill, excavations and resurfacing on public property will be done in accordance with the ordinances, policies, and procedures of the affected governing body and in accordance with the requirements of AWWA C-600.

May 13, 2014
Adopted by Commission Action